EMERGENCY PURCHASE REPORT

Name of Requestor: David Laughlin

Date: 10/26/2021

1. Date Critical or Emergency situation first noted/occurred (time and date):

9/18/2021 at 6:35 AM

2. Describe the danger to health, safety, property, or of equipment failure or economic loss – be very specific (attach additional pages, if required):

NEW JUSTIFICATION

On September 18, 2021, the 2 MW Cummins Standby Diesel Generator owned by the Water Authority experienced a control panel failure that rendered it unreliable for the process it was protecting (South Activated Pumping Station). A failure of this critical process will almost certainly result in an SSO and EPA violations/fines. To limit this exposure, the 2 MW Wagner Rental Generator previously approved under the Original Justification (see below) was quickly relocated from the South Blowers process to support the South activated Pumping Station. It must remain at this location until the control in the Cummins unit is repaired.

Shortly after the 2 MW rental unit was relocated, a new 3 MW Permanent Standby Diesel Generator was commissioned and placed in service for the South Blowers process. It continues to provide standby power for this important process.

Prior to its recent relocation, the 2 MW rental unit provided standby emergency power for the South Blowers from February 12, 2020 until its recent relocation to the South Activated Pumping Station on September 21, 2021.

ORIGNAL JUSTIFICATION

The SWRP North Cogeneration Facility is presently NOT operational and is expected to remain off line for the next 60 to 90 days as repairs are completed. The main bearings in both Generators #1 and #2 have failed and must be replaced. While repairs are being performed, SWRP remains at greater risk of losing all electrical power – a total black out condition. During this time, SWRP is relying primarily on PNM utility power to ensure all plant processes are operational. If we lose PNM power for any reason, GOGEN Generators #3 and #4 will also trip off line (they are too small to carry the plant electrical load by themselves) and the plant will have no power until some emergency portable generators can be started. These will only help maintain sewage flow through the plant and hopefully avoid a Sanitary Sewer Overflow (a serious EPA violation).

Because we will not be able to power the large blowers used in our Nitrogen Reduction Facilities, the longer the outage persists, the greater the likelihood we will violate our permit for Ammonia removal in our effluent outflow to the river. While this violation is not as onerous as a spill, avoiding it remains very important. A rented emergency generator deployed at the SWRP South Blower Building will enable the plant to meet its Nitrogen Removal permit requirements throughout this period of vulnerability.

Stanley R Allred

Chief Financial Officer

3.	3. Impact/consequences had purchase not been ma	ade immediately:
	The longer the SWRP operates without Nort	h COGEN, the greater the risk of a violation.
4.	4. Item(s) purchased:	
	Continued rental for a period of 60 days (thr Generator (480V Output).	ough 12/31/2021) of a 2 MW Emergency Portable
5.	5. Price:	
	\$30,025.22 per month (to include all taxes an	d fees) for a total of two (2) months = \$60,050.44.
6.	6. Vendors contacted to obtain best available price	:
		na Rd NE Albuquerque, NM 87109 (505) 345-8411 Z-85043Main: (904)-253-0202, Tollfree: 1-800-Aggreko
7.	7. Name and address of selected supplier:	
	Wagner Equipment Company; 4000 Osuna	Rd NE Albuquerque, NM 87109 (505) 345-8411
Em	Emergency purchases require review and acknowled	dgement from the Division Manager.
	Topie de L	10/28/21 14:11 MDT
Di۱	Division Manager	Date
Off	Emergency Purchases greater than \$10,000 require of Officer and Chief Financial Officer.	review and acknowledgement from the Chief Operating
	Chief Planning Officer	10/28/21 14:16 MDT Date

Critical or Emergency Purchases greater than \$100,000 require review and acknowledgement from the Executive Director.

Date

10/28/21 14:48 MDT

EMERGENCY PURCHASING

Mark S. Sanchez	11/1/21 09:56 MDT
Executive Director	Date
Review and Verification by Purchasing Officer:	
Joseph Joseph	11/1/21 10:49 MDT
Purchasing Officer	Date